

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE OF PAGES 1 OF 2
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 07 MARCH 2006	4. REQUISITION/PURCHASE REQ. NO. 36110/53365306	5. PROJECT NO. (If applicable)	
6. ISSUED BY NSWC CARDEROCK DIVISION 9500 MACARTHUR BLVD. W. BETHESDA MD 20817-5700	CODE N00167	7. ADMINISTERED BY (If other than Item 6) CODE		

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(✓)	9A. AMENDMENT OF SOLICITATION NO. N0016706Q0004
	×	9B. DATED (SEE ITEM 11) 30 JAN 2006
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	

### 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 0 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

### 12. ACCOUNTING AND APPROPRIATION DATA (If required)

### 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(✓) A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).

C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) THIS AMENDMENT IS BEING ISSUED TO PROVIDE ANSWERS TO QUESTIONS SUBMITTED BY POTENTIAL BIDDERS IN REFERENCE TO THE SOLICITATION IN BLOCK #9A. (see page 2)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)	16C. DATE SIGNED

1. **Question:** Is this an "all or nothing" award? **Answer:** Yes
2. **Question:** Who must supply the necessary shut-off valves, disconnects and/or junction boxes that are required to make final connections? **Answer:** Shut-off valves provided by General contractor. Remaining equipment such as disconnect switches and junction boxes are supplied by the KEC (kitchen equipment contractor).
3. **Question:** Will any other alternative(s) be considered in lieu of the chrome, steel or stainless steel for all exposed conduit (2.1 H)? **Answer:** EMT is acceptable.
4. **Question:** Confirm the type of final plumbing connections that are to be made by the General Contractor (2.3 E) vs those by the KEC. **Answer:** General Contractor will provide shut-off valves for plumbing stubout.
5. **Question:** How many construction and/or progress meetings are anticipated for the KEC to attend (3.1 C)? **Answer:** One
6. **Question:** All Custom Fabricated Items (ie: 052, 059, 064, 068, 071, 079, 085 and 093) refer to Detail 1.05 that requires the s/s framework to use "fully welded angle and channel construction". Is it acceptable to provide a "fully welded **uni-body** construction" that has proved to be superior in strength and integrity to angle and channel? **Answer:** Yes
7. **Question:** Item 029A identifies a 20 gal capacity kettle. Will a 25 gal capacity kettle be acceptable in lieu of the 20 gal size? **Answer:** Yes
8. **Question:** Item 093 is identified as a Cashier Stand in the specifications but is indicated as a "Spare" in the Equipment Schedule. Please confirm which is correct. **Answer:** Cashier Stands are a requirement of the project. An amendment has been sent out.
9. **Question:** General: a)has a Corian color and/or pattern been established for the tray slides for all custom fabrication Items (052,054,064,068,071,079,085 and 093)?; will there be multiple requirements or just one? **Answer:** Yes. Dupont Fossil. Thickness shall be 1/2". This is a correction to the original specifications.  
**Question:** b)has a laminate color and/or pattern been established for all the panels and edges for Items 048,052,059,064 and 068? **Answer:** Plastic laminate. Information is as follows:
  - Manufacturer is Pionite.
  - Reference Name is Suede.
  - Ref no is WM971-S.
  - Color / Pattern is Sugar Maple.